



INTRODUCTION TO BUILDING SIMULATION


Shreshth Nagpal






























SITE CLIMATE DATA

- LONGITUDE - 76.47 E
- LATITUDE - 30.44 N
- ALTITUDE - 304-365 METERS ABOVE MSL
- MONSOON - JULY TO SEPTEMBER
- TEMPERATURE -
WINTER - MIN. 1* C - 16* C (NOV. - JAN.)
SUMMER - MIN. 27* C - 44* C (APRIL - JULY)
- WIND DIRECTION - FROM NORTH WEST TO SOUTH EAST IN WINTER & REVERSE IN SUMMER

AVERAGE DAILY INCIDENT SOLAR RADIATION BY ORIENTATION





BUILDING PERFORMANCE ANALYSIS

1. The solar radiation analysis on the previous page clearly shows that roof surfaces receive the maximum average daily radiation through the year followed by the south-west facades.
2. The energy use characterization of a baseline design building defined by performance parameters mandated by ASHRAE standard 90.1-2004 illustrates that envelope loads result in almost half of the total cooling energy requirements of the building.
3. Daylight level analysis for both outdoor and indoor spaces illustrates that there may be potential discomfort conditions caused due to excessive radiation and high contrast situations.








To optimize the performance of the building, the design intent should be directed towards the following aspects:

- Reduction in direct solar radiation incident on building surfaces – especially during summers.
- Glare control and maximum visual comfort in both indoor and outdoor spaces throughout the year.
- Optimum daylight availability in regularly occupied spaces for maximum part of the year.

The chart on the right presents the annual energy use breakdown by end use and illustrates that half of the building energy is consumed by HVAC end uses comprising of Cooling, Heat Rejection, Pumping and Ventilation Fans.

Further Cooling load breakdown, as shown below, also suggests that 56% of the cooling load in the project is directly affected by the design of the building envelope. The rest is caused by heat gain from internal loads such as lighting and equipment.

ENERGY USE CHARACTERIZATION FOR ASHRAE CASE AND COMPARISON WITH DESIGNED ENVELOPE



PV OPPORTUNITY

R-13 SPANDREL
R-10 MASS WALLS
R-18 ROOF

R-13 SPANDREL
R-10 WALLS
R-18 ROOF

R-10 WALLS
R-18 ROOF

OPTION I

Heat Mirror Insulated
Aqua+ Clear, Low E


U: 0.25 (0.16cg)
SHGC/SC: 0.31/0.36
 T_{vis} : 0.48

BIPV OPPORTUNITY

U: 0.32 (0.23cg)
SHGC/SC: 0.09/0.10
 T_{vis} : 0.10

OPTION II

Low E, High Visibility
Color Neutral IGU



+40%Frit @
40%coverage






U: 0.41 (0.32cg)
SHGC/SC: 0.32/0.37
 T_{vis} : 0.70 (0.58effective)


OPTION III

Low E, Low Iron,
Color Neutral IGU




U: 0.41 (0.32cg)
SHGC/SC: 0.27/0.31
 T_{vis} : 0.63







DAYLIGHT AUTONOMY STUDY WITH DESIGNED SOUTH AND WEST WALL DESIGN




DAYLIGHT AUTONOMY STUDY WITH RECOMMENDED SOUTH AND WEST WALL DESIGN




EXISTING LOWER FLOOR PLAN



RECOMMENDED LOWER FLOOR PLAN OPTION






EXISTING UPPER FLOOR PLAN




RECOMMENDED UPPER FLOOR PLAN OPTION


ENERGY CONSUMPTION WITH DIFFERENT WINDOW HEIGHTS






Lights



HVAC



Total



The graphs on the left illustrate the optimization analysis for appropriate window heights. As can be seen, as window height is reduced daylight levels reduce resulting in increased lighting consumption.

Although there is a reduction in thermal losses with reduced windows, there is an increase in cooling energy gains because of the lighting associated heat gains.

The trade-off between thermal performance and lighting performance was analyzed for various window heights to determine the optimum window size.






It was found that at window heights equal to 7', there is minimum total energy consumption along with comfortable day light levels inside.

Area: 5787.8 sqft
 Azimuth: 162deg
 Altitude: 12.5deg
 Incident: 5.07kWh/sqm/day
 Generated: **115,901 kWh/yr**

Area: 6110.7 sqft
 Azimuth: -108deg
 Altitude: 12.5deg
 Incident: 4.80kWh/sqm/day
 Generated: **115,217 kWh/yr**

Area: 2234.55 sqft
 Azimuth: -108deg
 Altitude: 12.5deg
 Incident: 4.80kWh/sqm/day
 Generated: **42,132 kWh/yr**

Area: 9763.75 sqft
 Azimuth: -108deg
 Altitude: 12.5deg
 Incident: 4.80kWh/sqm/day
 Generated: **184,096 kWh/yr**



High Efficiency p-Si
 @ South Facing - Tilt Mounted

Framed Crystalline 4'x6'
 Nominal Power: 12W/sqft

Low Efficiency a-Si
 @ Horizontal - Roof Laminated

Opaque 0.1" thick Membrane
 Nominal Power: 5.8W/sqft

